

April 16<sup>th</sup> 2026

## Treatment Facility Overflow

Village Residents,

This serves as notice to the public of an overflow event that occurred during the early morning hours of April 14<sup>th</sup> at the Wastewater Treatment Facility located at 252 East Pioneer Park Road Westfield WI.

The event occurred during the hours of 3 am until about 3:40 am. The cause of the overflow was a result of excess rain within the village on already saturated soils. Raw sewage pumps were running at full capacity and when the RAS cycle enabled at 3 am, the existing splitter box overflowed causing approximately 6,000 gallons of sludge and raw sewage to spill onto the grass area and street.

The operator was notified of the high flows around 3:30 am via an alarm and immediately made corrective procedures.

As required of an overflow, the DNR was made aware of the situation within 24 hours and the proper data and cause was submitted to the DNR by village personnel.

Questions to this matter can be directed towards Joel Spoehr, DPW or Dennis Daye, WWTF Operator.